



## **Montana Fish, Wildlife & Parks**

### ADDENDUM NO. 1

---

TO: ALL BIDDERS OF RECORD

PROJECT: Freezeout Lake WMA Cold Storage Building

FWP PROJECT #: 7179102

DATE: March 13, 2018


FROM: Jeffrey L. Larson, P.E.

**Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.**

Bidders for the above listed project are hereby notified that the following changes have been made to the bid documents:

*1. Add the following to Construction Notes, Sheet C2 of the DRAWINGS:*

Metal building systems shall be accepted as a substitution to the post and frame building systems specified in the bid documents with the following conditions; rigid steel frame spacing shall not exceed 20-feet, metal roof and wall panels will be as specified for post and frame construction, and the building wall panels shall be connected to the footing-foundation system along their entire length. Final acceptance of a metal building system is subject to the approval of the Engineer and Owner.

  
Jeffrey L. Larson, P.E.

End of Addendum #1